



# Sanitary Sewer Overflow Annual Report

## Division of Surface Water

<b>Date:</b> 01/09/2026		
<b>Facility Name:</b> East Palestine WWTP		
<b>Ohio NPDES Permit Number:</b> 3PD00042*ND		
<b>Period Covered by Report:</b> 01/01/2025 - 12/31/2025		
<b>Contact Person:</b> Scott Wolfe	<b>Title:</b> Superintendent	
<b>Mailing Address:</b> PO Box 231		
<b>City:</b> East Palestine, OH	<b>State:</b> OH	<b>Zip Code:</b> 44413
<b>Country:</b> USA		
<b>Sanitary Sewer Overflows Spreadsheet(attachment) :</b>		
<b>Water In Basement Occurrences Spreadsheet(attachment) : WIB 2025.xlsxm</b>		
<b>Narrative analysis of WIB patterns by location, frequency and cause:</b> There is no pattern to the WIBs. 2 of these have been fixed. One was caused by roots in the mainline (that section was replaced). The other was a tap damaged during a waterline replacement project previously done. The Parkview Drive and Neely Manor blocks are now part of our more frequent maintenance areas.		

### ADDITIONAL INFORMATION

Please add any additional comments or attachments below.

### Certification

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

<b>Name:</b> Scott Wolfe	<b>Title:</b> Superintendent
<b>Signature(Electronically submitted by):</b> Scott Wolfe (User ID: Wolfesr10 )	<b>Submission Date:</b> 01/09/2026